



Structural Integrity Assessment

Product Ref.: TASBG6

Starbase Green 6mm with Axminster Carpet

Test ref: Castor-EG6

Product Report – Structural Integrity Assessment (Visual)²

Product Name : Starbase Green 6mm

Internal Product ID : n/a

Base Material : Starbase Green 6mm PU underlay bonded to plywood base

Method of Bonding to Base Material : Double stick installation with STK 950 Tackifier

Floor Covering : Axminster Carpet

Method of Bonding to Floor Covering : Double stick installation with STK 900 Carpet Adhesive

Testing Method¹ : BS EN 985:2001 (Method C)
 ISO 4918:2016 (Method C)

¹ Unless stated otherwise all specimens are conditioned for 24 hours at 20 (±2°C) and a relative humidity of 65% (±2%)

² Tested to BS EN 985:2001, ISO 4918:2016 by trained technicians, only relates to the sample as described in this report



UK Sales

Tel: 01706 23 88 10
Fax: 01706 21 47 37

International Sales

Tel: +44 (0)1706 23 88 25
Fax: +44 (0)1706 22 51 14

www.interfloor.com

Interfloor is accredited to
ISO 9001, 14001 & 45001

Structural Integrity Assessment

BS EN 985:2001, ISO 4918:2016 (Method C)

The specimen was cut from the sample and bonded to plywood board with tackifier, the floor covering was then fit on top of the specimen with carpet adhesive. The specimen was subjected to 25,000 revolutions of our Castor Testing Machine under 90kg Load weight over 3 castors. Inspections occurred at 10,000 and 25,000 cycles.

Characteristic of Floor Covering	Pass/Fail	
	10,000 cycles	25,000 cycles
Loosening, swelling or tearing of the covering	Pass	Pass
Delamination	Pass	Pass
Delamination/flaking of the backing material	Pass	Pass
Loss of cohesion and/or powdering of binders	Pass	Pass
Material destruction	Pass	Pass

The sample has met pass criteria for BS EN 985:2001, ISO 4918:2016 (Method C)*

Signed: 

Date: 11/06/25

Name: J. Robinson, on behalf of Interfloor Ltd.

* Report relates only to the sample as provided, this report is not verified by an accredited body



UK Sales
 Tel: 01706 23 88 10
 Fax: 01706 21 47 37

International Sales
 Tel: +44 (0)1706 23 88 25
 Fax: +44 (0)1706 22 51 14

www.interfloor.com
 Interfloor is accredited to
ISO 9001, 14001 & 45001