

CERTIFICATE

Certificate No.: PL 4600753 004

Project No.: 89211110

Holder: Estillon B.V.
Linie 25
5405 AR UDEN
The Netherlands

Product : **Underlayment: Floorfixx Comfort**
Total thickness : 10 mm
Total mass : 6185 gr/m²

Certified in combination with : Floorcovering: 2.5 mm LVT (glued)

On basis of the results of the tests specified below, we declare that the above specimen fulfils the requirements of the TÜV Rheinland Testmark **Noise Reduction** including **Regular Product Surveillance**. TÜV Testmark and Underlayments, Test Protocol Impact Sound – 2017 EV

NB: This certificate itself shall not be considered as a type examination certificate.

Performance properties	Requirement	Result
Impact sound improvement according ISO 10140 and ISO 717-2	$\geq 10 \text{ dB } \Delta L_{\text{lin}}$	Pass

Full details of the results can be found in the following report(s):

Reference	Date of issue	Result
Initial test report: 89211110.01en	02/03/2017	10 dB ΔL_{lin} & 20 dB ΔL_{w}

Arnhem, 2 March 2017

C.C.M. van Houten, Manager operations
Page 1 of 1