

CERTIFICATE

Certificate No.: PL 4600753 010
Project No.: 89218461

Holder: Estillon B.V.
Linie 25
5405 AR UDEN
The Netherlands

Product : **Underlayment: Black Square 5 mm**
Total thickness : 5 mm
Density : 35 kg/m³

Certified in combination with : Floorcovering: 7 mm click laminate

On basis of the results of the tests specified below, we declare that the above specimen fulfils the requirements of the TÜV Rheinland Testmark **Noise Reduction** including **Regular Product Surveillance**. TÜV Testmark and Underlayments, Test Protocol Impact Sound – 2017 EV

NB: This certificate itself shall not be considered as a type examination certificate.

Performance properties	Requirement	Result
Impact sound improvement according ISO 10140 and ISO 717-2	$\geq 10 \text{ dB } \Delta L_{\text{lin}}$	Pass

Full details of the results can be found in the following report(s):

Reference	Date of issue	Result
Initial test report: A3925-3-RA-001	07-12-2020	10 dB ΔL_{lin} & 21 dB ΔL_{w}

Arnhem, 09-03-2021

R. de Jonge, Managing director
Page 1 of 1