

# C E R T I F I C A T E

**Certificate No.: PL 4600753 011**  
**Project No.: 89218461**

**Holder:** Estillon B.V.  
Linie 25  
5405 AR UDEN  
The Netherlands

**Product** : **Underlayment: Duralay LVT Multi-fit 1.5 mm**  
Total thickness : 1.5 mm  
Total mass : 2500 gr/m<sup>2</sup>

Certified in combination with : Floorcovering: PVC Rigid click with underlay 6.5 mm

---

On basis of the results of the tests specified below, we declare that the above specimen fulfils the requirements of the TÜV Rheinland Testmark **Noise Reduction** including **Regular Product Surveillance**. TÜV Testmark and Underlays, Test Protocol Impact Sound – 2017 EV

NB: This certificate itself shall not be considered as a type examination certificate.

<b>Performance properties</b>	<b>Requirement</b>	<b>Result</b>
Impact sound improvement according ISO 10140 and ISO 717-2	≥ 10 dB Δ L <sub>lin</sub>	Pass

Full details of the results can be found in the following report(s):

<b>Reference</b>	<b>Date of issue</b>	<b>Result</b>
Initial test report: A3925-3-RA-001 (PVC Rigid click with underlay 6.5 mm)	07-12-2020	10 dB Δ L <sub>lin</sub> & 21 dB Δ L <sub>w</sub>

Arnhem, 09-03-2021

R. de Jonge, Managing director  
Page 1 of 1